



21 Griffin Road North
Windsor, CT 06095
(860) 298-6308
AIHA ACCREDITATION # 259 ID# 100122
Connecticut Certification No. PH-0426

METHOD 5

CLIENT: W.M. Norridgewok, ME

Lab. Log No.: 37382
TRC Proj. No.: 168156.0000.0000
Lab Proj. No.: 104966.5010.0000
Date Sampled: 09/03/09
Date Complete: 09/09/09

Results

Sample Number	Media	Particulate (mg)
M5/29-1-(1) Engine 1	Filter# 725	1.2
M5/29-1-(2) Engine 1	TB# 210	0.6
M5/29-2-(1) Engine 1	Filter# 682	ND<0.5
M5/29-2-(2) Engine 1	TB# 220	0.5
M5/29-3-(1) Engine 1	Filter# 683	0.7
M5/29-3-(2) Engine 1	TB# 123	ND<0.5
M5/29-1-(1) Engine 2	Filter# 684	ND<0.5
M5/29-1-(2) Engine 2	TB# 118	ND<0.5
M5/29-2-(1) Engine 2	Filter# 685	0.5
M5/29-2-(2) Engine 2	TB# 655	0.8
M5/29-3-(1) Engine 2	Filter# 686	0.9
M5/29-3-(2) Engine 2	TB# 258	ND<0.5

M5/29-blank-(1)	Filter# 675	ND<0.5
M5/29-blank-(1)	TB# 185	ND<0.5

Limit of detection = 0.5 mg

These test results meet all the requirements of NELAC. Results relate only to the samples tested as received by the laboratory.

Analyst: Helen Rimsa

QC Analyst: Kathleen Williamson

Reviewed by: _____
Laboratory Analyst

Approved *K Williamson*
Kathleen Williamson
Signatory: Laboratory Manager

Date Issued: _____